



TEST REPORT



Report No :URS/M/RID/24/1/81			
Dated : 02/01/2024			
Issued To : Infracare Maintance And Cleaning Services LLC -Shj BR		Annual Maintenance Contract of Water Testing for GEMS School	
Attention	Billy Joel		
Sample Condition(Receipt Temperature)	11.6°C	Sample Condition (On Site)	31.6°C
Customer Ref.No.	54066/ Dated 18/12/2023 Trf No.URS/SR/49275 / Sample ID: URS/F/M/SID/23 /12/3517	Sample Package & Quantity	1 L
Sample Name	Water: Rooftop Tank #01 - GEMS Millennium School -Sharjah - Legionella	Sampled by	Ali
Sample Type	Pre-Flush	Neutralizing Agent	Sodium Thiosulphate
Sample description	Colorless Liquid	Delivered by	Lab Representative
Batch No. /Lot No.	NA	Sampling Protocol	BS 7592:2022
Manufacturing Date	NA	Date of Sample Receipt	18/12/2023
Best before date	NA	Date of Analysis	19/12/2023
Other Details	NA	Date of Completion	29/12/2023

Note: The submitted samples are Drawn by the Laboratory.

Note: For any queries, please contact lab manager at labmanager@urslabs.com.

S.NO	Parameters	Unit	Test Method	Result	LPS: ACCEPTABLE LIMIT Dubai Municipality- Technical guidelines for legionella control in water system (DM-HSD -GU44-LCW-S2)
1	Legionella	/Litre	ISO 11731:2017	Absent	1000
Legionella pneumophila Serotype 1					Absent
Legionella pneumophila Serotype 2-15					Absent
Legionellaspp					Absent

Remarks: The sample analyzed is of satisfactory quality with respect to the above tested parameters and limit of specifications
Procedure Used: Matrix A; procedure 5, 7; Media: BCYE and GVPC

Test method Variation: None

Specification reference: Guidelines for the control of legionella in water system public health & safety department, Dubai municipality

Key words:

CFU –Colony forming Unit, ND-Not detected, EAPC-Estimated aerobic plate count, LPS-Limits as per standard, BAM – Bacteriological Analytical Manual, CMMEF-Compendium of methods for the Microbiological examination of foods. APHA-American public health association-Standard method for the examination of water and waste water 22 edition: 2012

Note: (1) The results relate only to the items tested, (2) The test report shall not be reproduced except in full without the written approval of the URS laboratory, (3) For details of the accredited scope, please contact laboratory or accreditation body website

Nidhila Ganga
Technical Manager- Microbiology

URS Testing Laboratory LLC
PO Box 377913
Tel : +971 48837115
E-Mail : info@urslabs.com
Web site : www.urslabs.com



-----END OF THE TEST REPORT-----